



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION  
**NOTICE OF ACCEPTANCE (NOA)**

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
T (786) 315-2590 F (786) 315-2599

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

**Curv-A-Tech Corporation**  
930 W. 23<sup>rd</sup> Street  
Hialeah, FL 33010

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER-Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami-Dade County) and/ or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

**DESCRIPTION: Series "300 STD" Aluminum Single Hung Window - N.I.**

**APPROVAL DOCUMENT:** Drawing No. **W98-25**, titled "S-300 (STD) Alum. Single Hung Wdw. (N.I.)", sheets 1 through 5 of 5, dated 03/25/98, with revision G dated 07/13/15, prepared by Al-Farooq Corporation, signed and sealed by Javad Ahmad, P.E., bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

**MISSILE IMPACT RATING: None.**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state, series, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/ or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **revises** NOA No. **11-0816.07** and consists of this page 1 and evidence pages E-1 and E-2, as well as approval document mentioned above.

The submitted documentation was reviewed by **Manuel Perez, P.E.**



*Handwritten signature and date: 7/16/15*

NOA No. 15-0409.12  
Expiration Date: November 12, 2016  
Approval Date: July 23, 2015  
Page 1

**Curv-A-Tech Corporation**

**NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED**

**A. DRAWINGS**

1. Manufacturer's die drawings and sections.  
*(Submitted under previous NOA's No. 11-0816.07 and 98-0513.06)*
2. Drawing No. **W98-25**, titled "S-300 (STD) Alum. Single Hung Wdw. (N.I.)", sheets 1 through 5 of 5, dated 03/25/98, with revision **G** dated 07/13/15, prepared by Al-Farooq Corporation, signed and sealed by Javad Ahmad, P.E.

**B. TESTS**

1. Test reports on: 1) Air Infiltration Test, per FBC, TAS 202-94  
2) Uniform Static Air Pressure Test, Loading per PA 202-94  
3) Water Resistance Test, per PA 202-94  
4) Forced Entry Test, per SFBC 3603.2 (b) and PA 202-94  
along with marked-up drawings and installation diagram of an aluminum single hung window, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL-6515**, dated March 18, 2011, signed and sealed by Marlin D. Brinson, P.E.  
*(Submitted under previous NOA No. 11-0816.07)*
2. Test reports on: 1) Air Infiltration Test, per PA 202-94  
2) Uniform Static Air Pressure Test, Loading per PA 202-94  
along with marked-up drawings and installation diagram of an aluminum single hung window, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL-1957** dated February 25, 1998, signed and sealed by Gilbert Diamond, P.E.  
*(Submitted under previous NOA #06-1204.02)*
3. Test reports on: 1) Air Infiltration Test, per PA 202-94  
2) Uniform Static Air Pressure Test, Loading per PA 202-94  
3) Water Resistance Test, per PA 202-94  
4) Forced Entry Test, per SFBC 3603.2 (b) and PA 202-94  
along with marked-up drawings and installation diagram of an aluminum single hung window, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL-1958** dated March 13, 1998, signed and sealed by Gilbert Diamond, P.E.  
*(Submitted under previous NOA #06-1204.02)*
4. Test reports on: 1) Air Infiltration Test, per PA 202-94  
2) Uniform Static Air Pressure Test, Loading per PA 202-94  
along with marked-up drawings and installation diagram of an aluminum single hung window, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL-1962** dated March 16, 1998, signed and sealed by Gilbert Diamond, P.E.  
*(Submitted under previous NOA #06-1204.02)*

  
Manuel Perez, P.E.  
Product Control Examiner  
NOA No. 15-0409.12

Expiration Date: November 12, 2016

Approval Date: July 23, 2015

**Curv-A-Tech Corporation**

**NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED**

**B. TESTS (CONTINUED)**

5. Test reports on: 1) Air Infiltration Test, per PA 202-94  
2) Uniform Static Air Pressure Test, Loading per PA 202-94  
3) Water Resistance Test, per PA 202-94  
4) Forced Entry Test, per SFBC 3603.2 (b) and PA 202-94  
along with marked-up drawings and installation diagram of an aluminum single hung window, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL-1942** dated March 3, 1998, signed and sealed by Gilbert Diamond, P.E.  
*(Submitted under NOA #06-1204.02)*

**C. CALCULATIONS**

1. Anchor verification calculations, structural analysis and complying with **FBC 5<sup>th</sup> Edition (2014)**, dated 02/24/15, prepared by Al-Farooq Corporation, signed and sealed by Javad Ahmad, P.E.  
2. Glazing complies with **ASTM E1300-09**

**D. QUALITY ASSURANCE**

1. Miami-Dade Department of Regulatory and Economic Resources (RER).

**E. MATERIAL CERTIFICATIONS**

1. None.

**F. STATEMENTS**




1. Statement letter of conformance, complying with **FBC 5<sup>th</sup> Edition (2014)** and of no financial interest, dated February 24, 2015, issued by Al-Farooq Corporation, signed and sealed by Javad Ahmad, P.E.

**G. OTHERS**

1. Notice of Acceptance No. **11-0816.07**, issued to Curv-A-Tech Corporation for their Series "300 STD" Aluminum Single Hung Window - NI. approved on 10/20/11 and expiring on 11/12/16.

  
Manuel Perez, P.E.  
Product Control Examiner  
NOA No. 15-0409.12

Expiration Date: November 12, 2016  
Approval Date: July 23, 2015



## SERIES 300 (STD) ALUMINUM SINGLE HUNG WINDOW

APPROVAL APPLIES TO SINGLE UNITS OR SIDE BY SIDE COMBINATIONS OF S.H./S.H. OR SINGLE HUNG WITH OTHER MIAMI-DADE COUNTY APPR'D WINDOWS USING MIAMI-DADE COUNTY APPROVED MULLIONS IN BETWEEN. LOWER DESIGN PRESSURE FROM WINDOWS OR MULLION APPROVAL WILL APPLY TO ENTIRE SYSTEM.

DESIGN LOAD RATING FOR THESE WINDOWS TO BE AS PER CHARTS SHOWN ON SHEET 2.

THIS PRODUCT HAS BEEN DESIGNED AND TESTED TO COMPLY WITH THE REQUIREMENTS OF THE FLORIDA BUILDING CODE INCLUDING HIGH VELOCITY HURRICANE ZONE (HVHZ).

WOOD BUCKS BY OTHERS, MUST BE ANCHORED PROPERLY TO TRANSFER LOADS TO THE STRUCTURE.

ANCHORS SHALL BE AS LISTED, SPACED AS SHOWN ON DETAILS, ANCHORS EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL DRESSING OR STUCCO.

ANCHORING OR LOADING CONDITIONS NOT SHOWN IN THESE DETAILS ARE NOT PART OF THIS APPROVAL.

A LOAD DURATION INCREASE IS USED IN DESIGN OF ANCHORS INTO WOOD ONLY.

ALL SHIMS TO BE HIGH IMPACT, NON-METALLIC AND NON-COMPRESSIBLE.

MATERIALS INCLUDING BUT NOT LIMITED TO STEEL/METAL SCREWS, THAT COME INTO CONTACT WITH OTHER DISSIMILAR MATERIALS SHALL MEET THE REQUIREMENTS OF THE FLORIDA BUILDING CODE.

DAY LIGHT OPG. DIMENSIONS 1/1 WDW.	
WINDOW WIDTHS	D. L. OPENINGS
19-1/8"	14-1/8"
26-1/2"	21-1/2"
37"	32"
53-1/8"	48-1/8"

DAY LIGHT OPG. DIMENSIONS 1/1 WDW.	
WINDOW HEIGHTS	D. L. OPENINGS
26"	9-3/4"
38-3/8"	15-15/16"
50-5/8"	22-1/16"
56"	24-3/4"
63"	28-1/4"
74-1/4"	33-7/8"

DAY LIGHT OPG. DIMENSIONS TRUE COLONIAL WDW.	
D.L. OPENING MAX. WIDTH = 11"	
D.L. OPENING MAX. HEIGHT = 13-7/16"	

WINDOWS NOT RATED FOR IMPACT.

INSTALLATION OF THIS PRODUCT IN THE HVHZ AREA REQUIRES THE USE OF APPROVED SHUTTERS OR EXTERNAL PROTECTION DEVICES COMPLYING WITH HVHZ REQUIREMENTS.

INSTALLATION OF THIS SYSTEM OUTSIDE THE HVHZ AREA SHALL MEET THE APPLICABLE REQUIREMENTS FOR WIND BORNE DEBRIS PROTECTION.

THIS NOA IS NOT VALID WITHOUT CORPORATE SEAL OF CURV-A-TECH CORPORATION AND A LABEL AFFIXED.

PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No.  
Expiration Date

By *Manuel Perez*  
Miami Dade Product Control

15-0409.12  
11/12/2016

Engr: JAVAD AHMAD  
CIVIL  
FLA. PE # 70592  
C.A.N. 3538

JUL 14 2015

**AL-FAROOQ CORPORATION**  
ENGINEERS & PRODUCT DEVELOPMENT  
1235 S.W. 87 AVE  
MIAMI, FLORIDA 33174  
TEL (305) 264-8100 FAX (305) 262-6978  
COMP-ANL\W98-25CT

S-300 (STD) ALUM SINGLE HUNG WDW. (N.I.)  
**CURV-A-TECH CORPORATION**  
930 W. 23rd STREET  
HIALEAH, FL 33010  
TEL (305) 888-9631 FAX (305) 888-9969


no	date	by	description
D	08.17.05		UPDATED FOR 2004 FBC
E	06.28.11		UPDATED TO 2007 FBC
F	02.26.15		UPDATED TO 2014 FBC
G	07.13.15		NO CHANGE THIS SHEET

date: 03-25-98  
scale: 1/2"=1'-0"  
dr. by: HAMID  
chk. by:

drawing no.  
**W98-25**  
sheet 1 of 5

DESIGN LOAD CAPACITY - PSF										
WINDOW DIMS.		NUMBER OF ANCHORS/JAMB	1 OVER 1						TRUE COLONIAL	
			DSB-ANNEALED GLASS		3/16"-ANNEALED GLASS		1/4"-ANNEALED GLASS		DSB-ANNEALED GLASS	
WIDTH	HEIGHT		EXT. (+)	INT. (-)	EXT. (+)	INT. (-)	EXT. (+)	INT. (-)	EXT. (+)	INT. (-)
19-1/8"	26"	4	55.3	78.0	55.3	90.0	55.3	90.0	53.3	78.0
26-1/2"		4	55.3	78.0	55.3	90.0	55.3	90.0	53.3	78.0
37"		4	55.3	78.0	55.3	90.0	55.3	90.0	53.3	78.0
53-1/8"		4	55.3	77.7	55.3	90.0	55.3	90.0	53.3	78.0
19-1/8"	38-3/8"	6	55.3	78.0	55.3	90.0	55.3	90.0	53.3	78.0
26-1/2"		6	55.3	78.0	55.3	90.0	55.3	90.0	53.3	78.0
37"		6	55.3	77.7	55.3	90.0	55.3	90.0	53.3	78.0
53-1/8"		6	55.2	55.2	55.3	76.7	55.3	76.7	53.3	64.8
19-1/8"	50-5/8"	6	55.3	78.0	55.3	90.0	55.3	90.0	53.3	78.0
26-1/2"		6	55.3	78.0	55.3	90.0	55.3	90.0	53.3	78.0
37"		6	55.3	68.2	55.3	90.0	55.3	90.0	53.3	78.0
53-1/8"		6	40.1	40.1	55.3	62.6	55.3	62.6	52.9	52.9
19-1/8"	58"	6	55.3	78.0	55.3	90.0	55.3	90.0	53.3	78.0
26-1/2"		6	55.3	78.0	55.3	90.0	55.3	90.0	53.3	78.0
37"		6	55.3	63.2	55.3	90.0	55.3	90.0	53.3	78.0
53-1/8"		6	39.2	39.2	55.3	57.3	55.3	57.3	48.3	48.3
19-1/8"	63"	6	55.3	78.0	55.3	90.0	55.3	90.0	53.3	78.0
26-1/2"		6	55.3	78.0	55.3	90.0	55.3	90.0	53.3	78.0
37"		6	55.3	59.1	55.3	90.0	55.3	90.0	53.3	78.0
53-1/8"		6	38.8	38.8	54.5	54.5	54.5	54.5	46.0	46.0
19-1/8"	74-1/4"	8	55.3	78.0	55.3	90.0	55.3	90.0	53.3	78.0
26-1/2"		8	55.3	64.3	55.3	90.0	55.3	90.0	53.3	78.0
37"		8	51.3	51.3	55.3	85.1	55.3	90.0	53.3	78.0
53-1/8"		8	-	-	50.0	50.0	50.0	50.0	-	-

NOTE:  
GLASS CAPACITIES ON THIS SHEET ARE  
BASED ON ASTM E1300-09 (3 SEC. GUSTS)  
AND FLORIDA BUILDING COMMISSION  
DECLARATORY STATEMENT DCA05-DEC-219



PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No. 15-0409-12  
Expiration Date 12/31/2016  
By *Manuel Sme*  
Miami Dade Product Control

Engr: JAVAD AHMAD  
CML  
FLA. PE # 70592  
C.A.N. 3538  
*[Signature]*  
JUL 14 2015

**AL-FAROOQ CORPORATION**  
ENGINEERS & PRODUCT DEVELOPMENT  
1235 S.W. 87 AVE  
MIAMI, FLORIDA 33174  
TEL (305) 264-8100 FAX (305) 262-6978  
COMP-ANL\W98-25CT

S-300 (STD) ALUM SINGLE HUNG WDW. (N.I.)





**CURV-A-TECH CORPORATION**  
930 W. 23rd STREET  
HIALEAH, FL 33010  
TEL (305) 888-9631 FAX (305) 888-9969

Revisions:

no	date	by	description
D	08.17.05		CHART REV.
E	06.28.11		UPDATED TO 2007 FBC
F	02.26.15		UPDATED TO 2014 FBC
G	07.13.15		REV. PER RER COMMENTS

date: 03-25-98  
scale: 1/2"=1'-0"  
dr. by: HAMID  
chk. by:

drawing no.  
**W98-25**  
sheet 2 of 5




WOOD BUCKS AND METAL STRUCTURE NOT BY CURV-A-TECH MUST SUSTAIN LOADS IMPOSED BY GLAZING SYSTEM AND TRANSFER THEM TO THE BUILDING STRUCTURE.

#### SEALANTS:

FRAME CORNERS, FRAME SILL INSTALLATION SCREWS, VENT CORNER SEAMS AND FIXED MEETING RAIL AT END SEALED WITH 'SCHNEE MOREHEAD SM 5504' SEALANT. OR EQUIVALENT

#### WEEP HOLES:

W1 = 1-1/2" LONG WEEP NOTCH AT 2-3/4" FROM EACH END  
W2 = 1-3/4" X 3/16" WEEP HOLE AT 3-1/2" FROM EACH END



#### TYPICAL ANCHORS: SEE ELEV. FOR SPACING

1/4" DIA. TAPCON BY 'ITW' (Fu=125 KSI, Fy=100 KSI)

1/4" DIA. ULTRACON BY 'ELCO' (Fu=177 KSI, Fy=155 KSI)

INTO 2BY WOOD BUCKS OR WOOD STRUCTURES  
1-1/2" MIN. PENETRATION INTO WOOD (HEAD/SILL/JAMBS)

THRU 1BY BUCKS INTO CONC. OR MASONRY  
1-1/4" MIN. EMBED INTO CONCRETE (HEAD/SILL)  
1-1/4" MIN. EMBED INTO CONC. OR MASONRY (JAMBS)

DIRECTLY INTO CONC. OR MASONRY  
1-1/4" MIN. EMBED INTO CONCRETE (HEAD/SILL)  
1-1/4" MIN. EMBED INTO CONC. OR MASONRY (JAMBS)

#14 SMS OR SELF DRILLING SCREWS (GRADE 2 CRS)

INTO METAL STRUCTURES  
STEEL : 1/8" THK. MIN. (Fy = 36 KSI MIN.)  
ALUMINUM : 1/8" THK. MIN. (6063-T5 MIN.)  
(STEEL IN CONTACT WITH ALUMINUM TO BE PLATED OR PAINTED)

#12 SMS OR SELF DRILLING SCREWS (GRADE 2 CRS)

INTO MIAMI-DADE COUNTY APPROVED MULLIONS (MIN. THK. = 1/8")  
(NO SHIM SPACE)

#### TYPICAL EDGE DISTANCE

INTO CONCRETE AND MASONRY = 2-1/2" MIN.  
INTO WOOD STRUCTURE = 1" MIN.  
INTO METAL STRUCTURE = 3/4" MIN.

WOOD AT HEAD, SILL OR JAMBS SG = 0.55 MIN.  
CONCRETE AT HEAD, SILL OR JAMBS f'c = 3000 PSI MIN.  
C-90 HOLLOW/FILLED BLOCK AT JAMBS f'm = 2000 PSI MIN.

PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No. 15-0409.12  
Expiration Date 11/12/2016  
By *[Signature]*  
Miami Dade Product Control

Engr: JAVAD AHMAD  
CIVIL  
FLA. PE # 70592  
C.N. 3538  
*[Signature]*  
JUL 14 2015

**af c**  
**AL-FAROOQ CORPORATION**  
ENGINEERS & PRODUCT DEVELOPMENT  
1235 S.W. 87 AVE  
MIAMI, FLORIDA 33174  
TEL (305) 264-8100 FAX (305) 262-6978  
COMP-ANL W98-25CT

S-300 (STD) ALUM SINGLE HUNG WDW. (N.I.)  
**CURV-A-TECH CORPORATION**  
930 W. 23rd STREET  
HIALEAH, FL 33010  
TEL (305) 888-9631 FAX (305) 888-9969




revisions:	no	date	by	description
	D	08.17.05		NO CHANGE THIS SHEET
	E	06.28.11		UPDATED TO 2007 FBC
	F	02.26.15		UPDATED TO 2014 FBC
	G	07.13.15		REV. PER PER COMMENTS

date: 03-25-98	scale: 1/2" = 1"	dr. by: HAMID	chk. by:
----------------	------------------	---------------	----------

drawing no.	W98-25
sheet	3 of 5



ITEM #	PART #	QUANTITY	DESCRIPTION	MATERIAL	MANUF./SUPPLIER/REMARKS
1	C-3001	1	FRAME HEAD	6063-T6	-
2	C-3002	1	FRAME SILL	6063-T6	-
3	C-3003	2	FRAME JAMB	6063-T5	-
4	C-3004	1	FIXED MEETING RAIL	6063-T6	-
5	C-3005	1	SASH TOP RAIL	6063-T6	-
6	C-3006	1	SASH BOTTOM RAIL	6063-T6	-
8	C-3007	2	SASH SIDE RAIL	6063-T5	-
9	#8 X 1"	AS REQD.	ASSEMBLY SCREWS	-	P.H. SMS
10	C-3085	4/ VENT	FACE GUIDES 3" FROM ENDS	NYLON	-
11	C-3009	2/ VENT	SASH LATCH AT 5-1/4" FROM ENDS	6063-T6	WITH S.S. LEAF SPRING
11A	-	2/ VENT	SASH LATCH AT 6" FROM ENDS	-	SULLIVAN AND ASSOC.
11B	#8 X 3/4"	2/ LATCH	LATCH INSTALLATION SCREWS	-	F.H. SMS
12	3017-G	AS REQD.	FIN SEAL PILE	-	ULTRAFAB
13	C-3011	AS REQD.	BULB WEATHER STRIP, DUROMETER 70±5 SHORE A	VINYL	CENTRAL PLASTICS
14	-	AS REQD.	SETTING BLOCKS, DUROMETER 80±5 SHORE A	EPDM	-
15	-	AS REQD.	ALUM GLAZING BEAD	ALUMINUM	ROLL FORMED
16	-	2	BLOCK & TACKLE BALANCE	-	5/8" BOX, BLANCE SYSTEMS OR EQUIV.
17	C-3010	AS REQD.	HORIZ. MUNTIN	6063-T6	-
18	C-3014	AS REQD.	VERT. MUNTIN	6063-T5	6063-T5 (ALUM)

PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No. **15-0409.12**  
Expiration Date **11/12/2016**  
By *Manuel Perez*  
Miami Dade Product Control

Engr: JAVAD AHMAD  
CML  
FLA. PE # 70592  
C.A.N. 1538  
*[Signature]*  
JUL 14 2015

**AL-FAROOQ CORPORATION**  
ENGINEERS & PRODUCT DEVELOPMENT  
1235 S.W. 87 AVE  
MIAMI, FLORIDA 33174  
TEL (305) 264-8100 FAX (305) 262-6978

COMP-ANL\W98-25CT

---

S-300 (STD) ALUM SINGLE HUNG WDW. (N.I.)  
**CURV-A-TECH CORPORATION**  
930 W. 23rd STREET  
HIALEAH, FL 33010  
TEL (305) 888-9631 FAX (305) 888-9969

COMP-ANL\W98-25CT

---

revisions:		date	by	description
D	06.17.05	NO	CH	NO CHANGE THIS SHEET
E	06.28.11	NO	CH	UPDATED TO 2007 FBC
F	02.26.15	NO	CH	UPDATED TO 2014 FBC
G	07.13.15	NO	CH	NO CHANGE THIS SHEET

---














date: 03-25-98	scale: 1/2" = 1"	dr. by: HAMID	chk. by:	
----------------	------------------	---------------	----------	--

---

drawing no.  
**W98-25**

sheet 4 of 5

no.  
**W98-25**



PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No. 15-0409.12  
Expiration Date 11/32/2016  
By *Manuel J. Lopez*  
Miami Dade Product Control

Engr: JAVAD AHMAD  
CIVIL  
FLA. PE # 70592  
C.A.N. 3538  
*[Signature]*  
JUL 14 2015

**af c**  
**AL-FAROOQ CORPORATION**  
ENGINEERS & PRODUCT DEVELOPMENT  
1235 S.W. 87 AVE  
MIAMI, FLORIDA 33174  
TEL. (305) 264-8100 FAX. (305) 262-6978  
COMP-ANL\W98-25CT

S-300 (STD) ALUM SINGLE HUNG WDW. (N.I.)  
**CURV-A-TECH CORPORATION**  
930 W. 23rd STREET  
HIALEAH, FL 33010  
TEL (305) 888-9631 FAX. (305) 888-9969

revisions:	no	date	description
	D	08.17.05	NO CHANGE THIS SHEET
	E	06.28.11	UPDATED TO 2007 FBC
	F	02.26.15	NO CHANGE THIS SHEET
	G	07.13.15	NO CHANGE THIS SHEET

date: 03-25-98  
scale: 1/2" = 1"  
dr. by: HAMID  
chk. by:  
drawing no.  
**W98-25**  
sheet 5 of 5